

SCOTT SPECIALTY GASES -- ISOBUTYLENE IN AIR -- 6665-01-214-8247

===== Product Identification =====

Product ID:ISOBUTYLENE IN AIR

MSDS Date:04/23/1992

FSC:6665

NIIN:01-214-8247

MSDS Number: BVRGC

=== Responsible Party ===

Company Name:SCOTT SPECIALTY GASES

Address:ROUTE 611 NORTH

City:PLUMSTEADVILLE

State:PA

ZIP:18949

Country:US

Info Phone Num:215-766-8861

Emergency Phone Num:215-766-8861; 908-7
54-7700

CAGE:51847

=== Contractor Identification ===

Company Name:SCOTT SPECIALTY GASES

Address:6141 EASTON RD (6141 ROUTE 611)

Box:310

City:PLUMSTEADVILLE

State:PA

ZIP:18934

Country:US

Phone:215-766-8861/ FAX: 215-766-0416

CAGE:51847

===== Composition/Information on Ingredients =====

Ingred Name:PROPENE, 2-METHYL-; (ISOBUTYLENE)

CAS:115-11-7

RTECS #:UD0890000

OSHA PEL:N/K

ACGIH TLV:N/K

Ingred Name:AIR, REFRIGERATED LIQUID; AIR COMPRESSED (UN1002, DOT); AIR
REFRIGERATE

D LIQUID (CRYOGENIC LIQUID) (UN1003) (DOT)

RTECS #:AX5271000

OSHA PEL:N/K

ACGIH TLV:N/K

===== Hazards Identification =====

LD50 LC50 Mixture:NONE SPECIFIED BY MANUFACTURER.

Routes of Entry: Inhalation:YES Skin:NO Ingestion:NO

Reports of Carcinogenicity:NTP:NO IARC:NO OSHA:NO

Health Hazards Acute and Chronic:ACUTE:CONCENTRATION OF ISOBUTYLENE IS THIS MIXTURE SHOULD NOT PRESENT ANY SYMPTOMS OF TOXICITY.
CHRONIC:NONE.

Explanation of Carcinogenicity

:NOT RELEVANT

Effects of Overexposure:NONE SPECIFIED BY MANUFACTURER.

Medical Cond Aggravated by Exposure:NONE.

===== First Aid Measures =====

First Aid:INGEST:CALL MD IMMEDIATELY . EYES:IMMEDIATELY FLUSH W/POTABLE WATER FOR A MINIMUM OF 15 MINUTES, SEEK ASSISTANCE FROM MD .
SKIN:FLUSH W/COPIOUS AMOUNTS OF WATER. CALL MD . INHAL:IMME DIATELY REMOVE VICTIM TO FRESH AIR. IF BREATHING HAS STOPPED, GIVE ARTIFICIAL RESPIRATION. IF BREATHING IS D
IFFICULT, GIVE OXYGEN.

===== Fire Fighting Measures =====

Flash Point:NONFLAMMABLE

Extinguishing Media:USE WHAT IS APPROPRIATE FOR SURROUNDING FIRE.

Fire Fighting Procedures:USE NIOSH/MSHA APPROVED SCBA & FULL PROTECTIVE EQUIPMENT . USE WATER SPRAY TO KEEP FIRE EXPOSED CYLINDERS COOL.

Unusual Fire/Explosion Hazard:COMPRESSED AIR AT HIGH PRESSURES WILL ACCELERATE THE BURNING OF FLAMMABLE MATERIALS.

===== Accidental Release Measures =====

Spill Release Procedures:EVACUATE & VENTILATE AREA. REMOVE LEAKING CYLINDER TO EXHAUST HOOD OR SAFE OUTDOORS AREA IF THIS CAN BE DONE SAFELY.

Neutralizing Agent:NONE SPECIFIED BY MANUFACTURER.

===== Handling and Storage =====

Handling and Storage Precautions:STORE IN WELL VENTILATED AREAS ONLY. KEEP VALVE PROT CAP ON CYLS WHEN NOT IN USE & SECURE CYL WHEN USING TO PROT FROM FALLING.

Other Precautions:USE SUITABLE HAND TRUCK TO M

OVE CYLS. PROT CYLS FROM
PHYSICAL DMG. DO NOT DEFACE CYLS/LBLS. MOVE CYL W/ADEQ HAND TRUCK.
CYL SHOULD BE REFILLED BY QUALIFIED PRODUCERS OF COMPRESSED GAS.
SHIPMENT OF COM PRESSED GAS CYL WHICH HAS NOT (SUPDAT)

===== Exposure Controls/Personal Protection =====

Respiratory Protection:USE NIOSH/MSHA APPROVED SCBA IN CASE OF
EMERGENCY OR NON-ROUTINE USE.
Ventilation:PROVIDE ADEQUATE GENERAL & LOCAL EXHAUST VENTILATION.
Protective Gloves:RUBBER GLOVES.
Eye Protec
tion:ANSI APPROVED CHEM WORKERS GOGGS .
Other Protective Equipment:WEAR SAFETY SHOES. A SAFETY SHOWER & EYEWASH
STATION SHOULD BE READILY AVAILABLE.
Work Hygienic Practices:NONE SPECIFIED BY MANUFACTURER.
Supplemental Safety and Health
OTHER PREC:BEEN FILLED BY OWNER OR WITH HIS WRITTEN CONSENT IS A
VIOLATION OF FEDERAL LAW (49 CFR).

===== Physical/Chemical Properties =====

HCC:G3
Boiling Pt:B.P. Text:-318F,-194C
Vapor Density:1.2
Spec Gravity:0.88 (H*2O=1)
Solubility in Water:INSOLUBLE
Appearance and Odor:COLORLESS GAS W/POSSIBLE SLIGHT OLEFINIC ODOR.
Percent Volatiles by Volume:100

===== Stability and Reactivity Data =====

Stability Indicator/Materials to Avoid:YES
NONE.
Stability Condition to Avoid:NONE SPECIFIED BY MANUFACTURER.
Hazardous Decomposition Products:NONE.

===== Disposal Considerations =====

Waste Disposal Methods:DISPOSAL MUST BE I/A/W FEDERAL, STATE & LOCAL
REGULATIO

NS . RETURN CYLS TO SUPPLIER FOR PROPER DISP W/ANY VALVE
OUTLET PLUGS/CAPS SECURED & VALVE PROT CAP IN PLACE. ALLOW GAS TO
DISCHARGE AT SLO W RATE TO ATM IN UNCONFINED AREA/EXHST HOOD.

Disclaimer (provided with this information by the compiling agencies):
This information is formulated for use by elements of the Department
of Defense. The United States of America in no manner whatsoever,
expressly or implied, warrants this information to be accurate and
disclaims all liability for
its use. Any person utilizing this
document should seek competent professional advice to verify and
assume responsibility for the suitability of this information to their
particular situation.